

No.	Question	Answer
1.	Please confirm that the gas bags DN720 (4 pcs.) has to be delivered by the Contractor;	In accordance with item 7.1.2 of Technical specification the gas stoppers shall be delivered by the Contractor. (Tehniskajā uzdevumā 7.1.2. punktā ir noteikts, ka nosprostošanas balonus piegādā Piegādātājs).
2.	Please confirm that the contractor will be able to prepare work documentation and schemes in English or Latvian languages;	Latvian language is preferable. (Vēlams latviešu valodā).
3.	Please clarify whether the electricity could be provided by Contracting Authority for the works;	The electricity will be provided by the Contracting entity (Conexus Baltic Grid). (Elektroenerģiju nodrošina Pasūtītājs).
4.	Please clarify whether the valves and actuators provided by Contracting authority will be painted as per your requirements and repainting will not be necessary;	Please see item 7.1.3. of Technical specification - Painting materials shall be provided by the Contractor. The following items shall be painted; valves, hydro-pneumatic actuators, welds and welded pipe spoons. Paint - White RAL 9017; Grey RAL 7040. (Tehniskais uzdevums 7.1.3 punkts. Krāsošanas materiāli. Būs jāpārkrāso noslēgarmatūra, hidropneimatiskā piedziņa, metinājuma vietas un iemetinātā spole. Baltā krāsa RAL 9017, Pelēkā krāsa RAL 7040)
5.	Please clarify the scope of materials necessary to supply for the connection of actuators;	Glands (seals for connection of power and control cables acc. Tech, spec.) and cables are included in the set of hydro pneumatic actuators. (Teorētiski visiem glendiem un vadiem jābūt komplektā ar hidropneimatisko piedziņu).

6.	Please specify 7.1.5 scope of delivery materials with the works for the connection of actuators (like type of the cable, distance, stainless steel pipes, etc.)	<p>The contractor scope of works includes:</p> <ul style="list-style-type: none"> -delivery of stainless steel tubing: diameter 10 mm; total length - 34 m - screws NPT 1/2" (pipes must be fixed to the frame of the existing trap) -stainless steel tubing installation works (replacement of the existing ones). <p>Nerūsējošā tērauda impulscaurules: diametrs 10 mm, aptuvenais kopējais garums 34 metri.</p> <p>Pieslēgumu vītnes NPT 1/2" (caurules ir jānostiprina uz esošā trapa rāmja)</p> <p>Ir jāveic impulslīnijas nerūsējošā tērauda uzstādīšana (t.i. esošo cauruļu nomaiņa)</p>
7.	Is the delivery of the hydraulic fluid (120 ltr. Aeroshells fluid 41) is within the scope of contractor;	<p>In accordance with the item 7.1.4. of Technical specification hydraulic fluid 120 ltr shall be delivered by the Contractor.</p> <p>The fluid (Aeroshells fluid 41) is used for hydropneumatic actuators at Incukalns UGS.</p> <p>(Tehniskajā uzdevumā 7.1.4 Aeroshells fluid 41 piegādā pretendents (IPGK hidropneimatiskajām piedziņām tiek izmantota šī eļļa).</p>
8.	Please confirm that the concrete supports for the ball valves can be premanufactured earlier and delivered to the work site during work period.	<p>In our practice the new supports are usually made on a basis of the existing supports, but the Tenderer may also supply pre-fabricated supports under conditions that he will ensure an accurate set of the supports and not settling them down over time.</p> <p>(Pārsvarā pamatus veido uz esošo pamatu veidnēm, bet ja pretendents spēj nodrošināt pamatu precīzu uzstādīšanu un kad tie laika gaitā nenosēžas</p>
9.	Having read the tender documents of the tender no. PRO-2019/153 ("Gāzes kompresoru ceĶa Nr.2 pirmās pakāpes pārsūkņēšanas agregāta Nr.3 krāna Nr.III-2 un pirmās pakāpes gāzespārsūkņēšanas agregāta Nr.5 krāna Nr.V-2 nomaiņas darbi"), we kindly ask AS Conexus Baltic Grid to clarify the issue regarding the process of submission of an electronic tender offer, i.e. should it be submitted in the envelope, the number of electronic copies submitted (if any) etc.	<p>Electronic tender signed with safe electronic signature according clause 8.1.2. should be put in closed envelope for the reason we can't get access to it. There is no need for paper copy.</p> <p>Clause 8.1.1. requests for paper original + scanned version of an original.</p>